

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 778

Dated: 16-06-2023

It is certified that an inspection team headed by Sh. Des Raj Jambhwal Engineer

(Name of Officers with designation) from Water Supply & Sanitation Subdiv-2 Balachaur

(Name of Department/ Office) inspected the M.R. CITI PUBLIC SCHOOL, BHADDI ROAD,

BALACHAUR (DISTT. SBS NAGAR) (Name & Address of the school) on 15-06-2023 (date of


inspection) and found that the M.R. CITI PUBLIC SCHOOL, BHADDI ROAD, BALACHAUR

(DISTT. SBS NAGAR) (Name of school) has safe drinking water facilities for the students and

members of staff of the institution and is maintaining the hygienic sanitation condition in the

school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of One year.

Signature with Seal : 

Name : RAMANDEEP SINGH

Designation : SUB. Div. Enngg.


Name & Address of the Office / Department :

To

M. R. CITI PUBLIC SCHOOL


BALACHAUR

(Name & Address of the Institution)


Sub. Div. Engineer
W/S. & Sanitation Sub. Div-2
Balachaur


Principal

M.R. Citi Public School
Balachaur (SBS Nagar)


Chairman
M.R. CITI PUBLIC SCHOOL
Balachaur, District SBS Nagar (Punjab)

DISTRICT WATER TESTING LABORATORY, SBS NAGAR

District Water Testing Laboratory, Department of Water Supply and Sanitation, Village Saloh, SBS Nagar, Punjab
dwtlsbs@gmail.com



TEST REPORT

Name & Address of Customer : M.R. CITI Public School Balachaur M.R. CITI Public School Balachaur, SBS Nagar		Customer Reference No.	No : Ref.No. MRCPS/23-24/5774 Dated : 02/06/2023
		Sample Submitted by	Mr. Suresh Kumar
		Date of Sample Receipt	05/06/2023
		Analysis Starting Date	05/06/2023
		Analysis completion Date	06/06/2023
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC988123000000111F	Sample Type :	Water
Test Report No.:	DWTLSBS/2324/00077	Date of Issue :	13/06/2023
Registration no.:	DWTLSBS/REG2324/00185	Condition of Sample :	Unsealed
Collection Point:	NA	Quantity/Type of Bottle:	2000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	M.R. CITI Public School Balachaur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	SBS Nagar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.38	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	110	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.7	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	80	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	88	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	19.23	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	9.72	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	12	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

[Signature]
Principal

M.R. CITI PUBLIC SCHOOL
Balachaur, District SBS Nagar (Punjab)
Balachaur (SBS Nagar)

[Signature]
Chairman

M.R. CITI PUBLIC SCHOOL
Balachaur, District SBS Nagar (Punjab)

[Signature]

Mr. Praveen Singh Danu
Chemist/Analyst
Authorized Signatory
For, District Water Testing Laboratory
SBS Nagar

End of the Test Report